

GL SpectroSoft Report
Lighting Research & Measurement Center


Measurement name: *B3761_F_20230907_M_S*
 Measurement time: *2023-09-07T07:59:51*
 Report time: *2023-09-13*
 Device: *GL SPECTIS 1.0 Touch + Flicker*
 Sensor Temperature: *28.82°C*

Client name: *LED line LITE*
 Model name: *Światłówka LED T8 22W 6500K 2265lm*
220-240V 150cm
 Item No: *202054*
 Serial No.: *21405*
 Made by: *Radosław Kośnik*

Flicker

Flicker	100 Hz
Flicker index	0.001115
Flicker percent	0.83 %
SVM	0.0098

Flicker chart



FFT chart

