

GL SpectroSoft Report  
Lighting Research & Measurement Center


Measurement name: *B3677\_F\_20230727\_M\_S*  
 Measurement time: *2023-07-27T13:50:13*  
 Report time: *2023-08-10*  
 Device: *GL SPECTIS 1.0 Touch + Flicker*  
 Sensor Temperature: *28.75°C*

Client name: *LED line PRIME*  
 Model name: *Plafon ACTON 18W 2000lm 4000K IP54 kwadrat*  
 Item No: *201170*  
 Serial No.: *11303*  
 Made by: *Radosław Kośnik*

### Flicker

Flicker	100 Hz
Flicker index	0.006827
Flicker percent	3.25 %
SVM	0.0347

### Flicker chart



### FFT chart

