

GL SpectroSoft Report
Lighting Research & Measurement Center


Measurement name: B4857_F_20250304_M_S
Measurement time: 2025-03-04T12:15:14
Report time: 2025-03-05
Device: GL SPECTIS 1.0 Touch + Flicker
Sensor Temperature: 24.5°C

Client name: LED line LITE
Model name: Panel Backlit 2in1 40W 4000K
4000LM 295x1195 Biały LITE
Item No: 203945
Serial No.: 12411
Made by: Radosław Kośnik

Flicker

Flicker	101 Hz
Flicker index	0.000819
Flicker percent	0.54 %
SVM	0.0025

Flicker chart



FFT chart

