

GL SpectroSoft Report  
Lighting Research & Measurement Center


Measurement name: *B3977\_F\_20240104\_M\_S*  
 Measurement time: *2024-01-04T13:11:28*  
 Report time: *2024-06-24*  
 Device: *GL SPECTIS 1.0 Touch + Flicker*  
 Sensor Temperature: *26.7°C*

Client name: *LED line PRIME*  
 Model name: *Oprawa HighBay PHANTOM 190 100W 4000K 19000lm 1-10V 120°*  
 Item No: *203143*  
 Serial No.: *44509*  
 Made by: *Radosław Kośnik*

### Flicker

Flicker	100 Hz
Flicker index	0.000848
Flicker percent	0.59 %
SVM	0.0057

### Flicker chart



### FFT chart

