

GL SpectroSoft Report
Lighting Research & Measurement Center


Measurement name: B4211_F_20240412_M_S
Measurement time: 2024-04-12T09:37:58
Report time: 2026-02-25
Device: GL SPECTIS 1.0 Touch + Flicker
Sensor Temperature: 30.63°C

Client name: LED line PRIME
Model name: Oprawa hermetyczna LINKER 4000K
30W 4500lm IP65 120cm szara PRIME
Item No: 203709
Serial No.: 65711
Made by: Radosław Kośnik

Flicker

Flicker	120 Hz
Flicker index	0.000974
Flicker percent	0.68 %
SVM	0.0046

Flicker chart



FFT chart

