GL SpectroSoft Report


Lighting Research & Measurement Center

Measurement name:	*B6569_F_20261028_M_S*	Client name:	*LED line PRIME*
Measurement time:	*2026-10-28T10:31:08*	Model name:	*Panel Backlit 4000K 40W 4800lm IP20 60x60cm biały PRIME*
Report time:	*2026-10-28*		
Device:	*GL SPECTIS 1.0 Touch + Flicker*	Item No:	*260160*
Sensor Temperature:	28.66°C	Serial No.:	*11005*
		Made by:	*Radosław Kośnik*

Flicker

Flicker	100 Hz
Flicker index	0.001696
Flicker percent	1.13 %
SVM	0.0165

Flicker chart



FFT chart

